

MANUFACTURER'S DECLARATION OF CONFORMITY

We:

SensoPart Industriesensorik GmbH

Am Wiedenbach 1

D-79695 Wieden/Schwarzwald

Tel.: + 49 (0) 76 73 / 8 21- 0

Fax: + 49 (0) 76 73 / 8 21- 30

declare under our own responsibility that the product(s):

FT 55-RL(2)AM-320-PNSUID(L)-xxx(xx) IO-Link Device

() = optional element

x = any character

to which this declaration refers conform to:

- ☒ IO-Link Interface and System Specification, V1.1.2, July 2013
(NOTE 1,2)
- ☒ IO Device Description, V1.1, August 2011
- ☐ Additional conformance to Device Profiles
(If checked refer to Part A on page 2)
- ☒ Conformance exceptions
(If checked refer to Part B on page 2)

The conformity tests are documented in the test report(s):

184-00009_1_Freigabetest.pdf

184-00010_1_Freigabetest.pdf

184-00020_1_Freigabetest.pdf

Issued at Gottenheim, 22.03.2022

Authorized signatory

Name: *Tobias Sexauer*

Title: *Head of Certification*

Signature:



Reproduction and all distribution without written authorization prohibited

NOTE 1 Relevant Test specification is CorrVersion 1.1.2, Feb. 2021

NOTE 2 Additional validity in Package 2015 and Corrigendum

MD-Version: V1.1.2 / 2021-12

Part A - Additional conformance to Device Profiles

	Specification
☐	IO-Link Common Profile Specification, V1.0, July 2017
☐	IO-Link Profile BLOB Transfer & Firmware Update Specification, V1.1, Sept. 2019
☐	IO-Link Smart Sensors 2 nd Edition Specification, V1.0, March 2017
☐	IO-Link Smart Sensors 2 nd Edition Specification, V1.1, Sept. 2021

Part B - Conformance exceptions

We herewith declare the following deviations to the related specifications	Reason
TC_0112 not passed	Changes to TC_0112 and TC_0113 in CorrVersion 1.1.2 of test specification from Feb. 2021 lead to failing tests for some old devices. CR is available (ID 236).